



KENSINGTON FIRE RESCUE
124 AMESBURY ROAD KENSINGTON, NH 03833
Business (603) 772- 5751 Fax (603)772-8213
www.town.kensington.nh.us/



**APPLICATION TO INSTALL A
FLAMMABLE OR COMBUSTIBLE LIQUID
UNDERGROUND STORAGE TANK**

All work shall comply with NH DES rules, NFPA 30 Flammable and Combustible Liquids Code and NPFA 1 Uniform Fire Code, (editions as adopted by NH Fire Code and local ordinance).

This application is to install, repair, or alter any stationary tank(s) for the storage of flammable or combustible liquids and shall be accompanied by a general description of the proposed work. It shall also include one copy of a drawing indicating location, use, capacity, and piping arrangement of all existing and proposed tank locations, or which are to be located upon the premises and all adjacent buildings and property lines.

This Fire Department requires that a letter from the New Hampshire Dept. of Environmental Service be submitted before a permit will be issued. This letter must state that the work will meet their requirements and they have issued a state permit for the work.

The Fire Official shall be notified not less than 3 days in advance so that they may witness:

- a. The tank has an approved identification label affixed to it.
- b. Air test with all connecting line in place and BEFORE tank(s) are covered.
- c. Any grounding, bonding or anode bag devices.

WORK SHALL NOT BEGIN WITHOUT FIRST SECURING A PERMIT. THIS IS NOT A PERMIT.

You may email the application to : 24chief1@comcast.net or mail.

Permit Fee of \$25.00 shall be made payable to the Town of Kensington, NH

Date of Application: _____

Name of Property: _____

Address of Property: _____

Name of Company: _____

Address of Company: _____

Telephone #: _____ Email: _____

For Office Use Only:

Date Received: _____ Check #: _____ Permit #: _____

Date Work Will Begin: _____

(2005)